

Disability Rights of West Virginia (DRWV) is the federally mandated protection and advocacy system for people with disabilities in West Virginia. One of DRWV's grants is Protection and Advocacy for Voting Access (PAVA). The PAVA grant program allows DRWV to ensure that individuals with disabilities can access full participation in the election process.

Title II of the Americans with Disabilities Act (ADA) requires state and local governments (public entities) to ensure that people with disabilities have a full and equal opportunity to vote. The ADA's provisions apply to all aspects of voting, including polling places. People with disabilities must have the opportunity to be full participants in an integrated civic event.

On January 4-22, 2021, we completed exterior accessibility monitoring of all precincts in Kanawha County. The majority of the polling sites in your county are accessible or can easily be made temporarily accessible designating accessible parking, hanging appropriate signage, and/or keeping doors opened. As such, the following ADA codes have been referenced below.

206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve.

216.6 Entrances. Where not all entrances comply with 404, entrances complying with 404 shall be identified by the International Symbol of Accessibility complying with 703.7.2.1. Directional signs complying with 703.5 that indicate the location of the nearest entrance complying with 404 shall be provided at entrances that do not comply with 404.

309.4 Operable parts shall be operable with one hand and shall not require tight grasping, pinching, or twisting of the wrist. The force required to activate operable parts shall be 5 pounds (22.2 N) maximum.

502.2 Vehicle Spaces. Car parking spaces shall be 96 inches (2440 mm) wide minimum and van parking spaces shall be 132 inches (3350 mm) wide minimum, shall be marked to define the width, and shall have an adjacent access aisle complying with 502.3. EXCEPTION: Van parking spaces shall be permitted to be 96 inches (2440 mm) wide minimum where the access aisle is 96 inches (2440 mm) wide minimum.

502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation "van accessible." Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.

The **2010 ADA Standards for Accessible Designs** referenced in this report can be found online at:

https://www.ada.gov/regs2010/2010ADASTandards/2010ADASTandards_prt.pdf

Before further review, please take time to browse the Standards to gain a better understanding of the issues addressed. The tables on the following pages list the ADA Standards and ADA Title II regulations, if applicable, for each area we monitored, the issues noted at each site, if any, and suggestions for meeting ADA compliance on election days.

Alum Creek Elementary	
Issue(s)	Door handle is not accessible
2010 ADA Standards for Accessible Design Requirements	309.4 Operable parts shall be operable with one hand and shall not require tight grasping, pinching, or twisting of the wrist. The force required to activate operable parts shall be 5 pounds (22.2 N) maximum.
Suggestions for ADA Compliance	Door handle should be a lever or handle rather than a knob that requires a tight grip and turning motion to open.

Andrew Jackson Middle School	
Issue(s)	The accessible parking sign is too low to the ground.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Ann Bailey Elementary School	
Issue(s)	Broken pavement
2010 ADA Standards for Accessible Design Requirements	206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve. 302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.
Suggestions for ADA	Repave or cover area of pavement that has been damaged. Make sure that it is covered to make a smooth surface.

Camp Virgil Tate	
Issue(s)	Accessible parking signage is not displayed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Capital High School	
Issue(s)	Accessible parking is not properly identified or at the right height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation. Install sign with the International Symbol of Accessibility.

Cedar Grove Community School	
Issue(s)	Accessible parking located at the back of the building; accessible entrance is in the front. Unstable surface outside of accessible entrance. No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	<p>303.4 Changes in level greater than ½ inch (13 mm) high shall be ramped and shall comply with 405 or 406.</p> <p>208.3.1 Parking spaces complying with 502 that serve a particular building or facility shall be located on the shortest accessible route from parking to an entrance complying with 206.4</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>208.3.1 General. Parking spaces complying with 502 that serve a particular building or facility shall be located on the shortest accessible route from parking to an entrance complying with 206.4. Where parking serves more than one accessible entrance, parking spaces complying with 502 shall be dispersed and located on the shortest accessible route to the accessible entrances. In parking facilities that do not serve a particular</p>

	building or facility, parking spaces complying with 502 shall be located on the shortest accessible route to an accessible pedestrian entrance of the parking facility.
Suggestions for ADA Compliance	Allow for temporary accessible parking spots on Election Day. Allow for wedge or surface height change on curb by main road. Install accessible parking signage to the required height that complies with the ADA regulation.

Chandler Academy	
Issue(s)	Accessible parking signage is not displayed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Chesapeake Elementary	
Issue(s)	No marked accessible parking and threshold ramp is too steep to enter the building.
2010 ADA Standards for Accessible Design Requirements	405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12. 208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.
Suggestions for ADA Compliance	Allow for temporary accessible parking spots during Election Day. Regrade ramp into building.

Dunbar City Hall	
Issue(s)	Unstable surface on the route to the main entrance
2010 ADA Standards for Accessible Design Requirements	302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. 206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve.

Suggestions for ADA Compliance	Repave area where the pavement has become broken.
---------------------------------------	---

Dunbar Middle School	
Issue(s)	Broken pavement at entry of cross walk
2010 ADA Standards for Accessible Design Requirements	206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve. 302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.
Suggestions for ADA Compliance	Repave area with broken and uneven concrete at the beginning of the crosswalk going from parking lot to the main school entrance.

Dunbar Recreation Center	
Issue(s)	Accessible parking sign is not displayed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Elizabeth Memorial Church	
Issue(s)	Accessible parking sign is not displayed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Elk Elementary School	
Issue(s)	Broken or uneven concrete and accessible parking sign is not displayed at the proper height

<p>2010 ADA Standards for Accessible Design Requirements</p>	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.</p>
<p>Suggestions for ADA Compliance</p>	<p>Remount existing signage to the required height that complies with the ADA regulation. Repave or patch cracked area.</p>

<p>Elkview Baptist Church</p>	
<p>Issue(s)</p>	<p>Accessible Parking sign is not displayed at the proper height.</p>
<p>2010 ADA Standards for Accessible Design Requirements</p>	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
<p>Suggestions for ADA Compliance</p>	<p>Remount existing signage to the required height that complies with the ADA regulation.</p>

<p>First Baptist Church</p>	
<p>Issue(s)</p>	<p>No marked accessible parking. Certain parking spots are at a high slope. There are no handrail extensions. Door handle is not accessible.</p>
<p>2010 ADA Standards for Accessible Design Requirements</p>	<p>505.10.1 Top and Bottom Extension at Ramps. Ramp handrails shall extend horizontally above the landing for 12 inches (305 mm) minimum beyond the top and bottom of ramp runs. Extensions shall return to a wall, guard, or the landing surface, or shall be continuous to the handrail of an adjacent ramp run.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign</p> <p>208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking <i>facility</i> is provided on a <i>site</i>, the number of <i>accessible spaces</i> provided on the <i>site</i> shall be</p>

	<p>calculated according to the number of <i>spaces</i> required for each parking facility.</p> <p>404.2.7 Door hardware is operable with one hand and does not require tight grasping, pinching, or twisting of the wrist.</p> <p>502.4 Floor or Ground Surfaces. Parking spaces and access aisles serving them shall comply with 302. Access aisles shall be at the same level as the parking spaces they serve. Changes in level are not permitted. EXCEPTION: Slopes not steeper than 1:48 shall be permitted.</p> <p>Advisory 502.4 Floor or Ground Surfaces. Access aisles are required to be nearly level in all directions to provide a surface for wheelchair transfer to and from vehicles. The exception allows sufficient slope for drainage. Built-up curb ramps are not permitted to project into access aisles and parking spaces because they would create slopes greater than 1:48.</p>
Suggestions for ADA Compliance	<p>Install handrail extensions, re-stripe the parking lots, assuring that there is the minimum # of accessible spaces, including van accessible, parking spaces. Replace the inaccessible knob with level, loop or push hardware. Assign accessible parking in places with level parking with a ratio below 1:48. Add accessible signage to the required height that complies with the ADA regulation.</p>

First Presbyterian Church	
Issue(s)	No accessible parking signs. Certain parking spots are at a slope that is too steep.
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>502.4 Floor or Ground Surfaces. Parking spaces and access aisles serving them shall comply with 302. Access aisles shall be at the same level as the parking spaces they serve. Changes in level are not permitted. EXCEPTION: Slopes not steeper than 1:48 shall be permitted.</p> <p>Advisory 502.4 Floor or Ground Surfaces. Access aisles are required to be nearly level in all directions to provide a surface for wheelchair transfer to and from vehicles. The exception allows sufficient slope for drainage. Built-up curb ramps are not permitted to project into access aisles and parking spaces because they would create slopes greater than 1:48.</p>
Suggestions for ADA Compliance	Add accessible signage to the required height that complies with the ADA regulation. Designate accessible parking spots in area with a level ground and a slope ratio less than 1:48.

First United Methodist Church	
Issue(s)	Accessible Parking sign is not displayed at the proper height.

2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Flinn Elementary School	
Issue(s)	No accessible parking signs.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Add accessible signage to the required height that complies with the ADA regulation.

Freewill Baptist Church	
Issue(s)	Marked accessible parking spot is in the road, door handle is not accessible, no handrail extension and entry ramp is too steep.
2010 ADA Standards for Accessible Design Requirements	<p>405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12 (8.3%).</p> <p>405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.</p> <p>404.2.7 Door hardware is operable with one hand and does not require tight grasping, pinching or twisting of the wrist.</p> <p>208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van</p>

	accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 208.2.4 Van Parking Spaces. For every six or fraction of six parking <i>spaces</i> required by 208.2 to comply with 502, at least one shall be a van parking <i>space</i> complying with 502.
Suggestions for ADA Compliance	Re-stripe the parking lots, assuring that there is the minimum # of accessible, including van accessible, parking spaces. Extend or redesign the ramps to meet requirements. Install handrails at the required 34-38 inches, and handrail extensions as required by the ADA. Replace the inaccessible knob with level, loop or push hardware.

Garnet Adult Center	
Issue(s)	Broken pavement along accessible entrance.
2010 ADA Standards for Accessible Design Requirements	206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve. 302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.
Suggestions for ADA Compliance	Repave area that has uneven or broken pavement.

George Washington High School	
Issue(s)	Handrails are too tall, no handrail extensions, and certain parts of the ramp are too steep.
2010 ADA Standards for Accessible Design Requirements	206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site. 405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12 (8.3%). 405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.
Suggestions for ADA Compliance	Install handrails at the required 34-38 inches, and handrail extensions as required by the ADA. Regrade access ramp where the slope exceeds 8.3% (corner/turning point).

Handley Community Center	
Issue(s)	No marked accessible parking.
2010 ADA Standards for Accessible	208.2 Minimum Number. Parking <i>spaces</i> complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking <i>facility</i> is provided on a <i>site</i> , the number of <i>accessible spaces</i> provided on the <i>site</i> shall be

Design Requirements	<p>calculated according to the number of <i>spaces</i> required for each parking <i>facility</i>.</p> <p>208.2.4 Van Parking Spaces. For every six or fraction of six parking <i>spaces</i> required by 208.2 to comply with 502, at least one shall be a van parking <i>space</i> complying with 502.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	<p>Provide ADA recommended number of accessible parking spots, add ADA recommended striping with adequate spacing, and signage that fits the ADA criteria. Add accessible signage to the required height that complies with the ADA regulation.</p>

Hansford Community Center	
Issue(s)	<p>Accessible parking sign is not displayed at the proper height. No handrail extensions.</p>
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.</p>
Suggestions for ADA Compliance	<p>Install handrails with proper extensions. Remount existing signage to the required height that complies with the ADA regulation.</p>

Hayes Middle School	
Issue(s)	<p>Accessible parking signs are not properly displayed.</p>
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	<p>Add accessible signage to the required height that complies with the ADA regulation. Consider repainting the spots.</p>

Hernshaw Methodist Church	
Issue(s)	<p>No handrail extensions. Accessible parking signage not properly displayed.</p>

2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.
Suggestions for ADA Compliance	Remount existing signs to comply with ADA criteria. Add handrail extensions as shown above.

Holz Elementary	
Issue(s)	Two drain grates placed on the accessible walkway. Accessible parking signage not displayed properly.
2010 ADA Standards for Accessible Design Requirements	302.3 Openings. Openings in floor or ground surfaces shall not allow passage of a sphere more than ½ inch (13 mm) diameter except as allowed in 407.4.3, 409.4.3, 410.4, 810.5.3 and 810.10. Elongated openings shall be placed so that the long dimension is perpendicular to the dominant direction of travel. 502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	On Election Day, cover grates with compliant mat or board. Remount existing signage to the required height that complies with the ADA regulation.

Horace Mann Elementary	
Issue(s)	No accessible parking signage displayed.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Add accessible signage to the required height that complies with the ADA regulation.

Jefferson Volunteer Fire Department	
Issue(s)	Large pothole in the accessible parking spot.
2010 ADA Standards for	206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger

Accessible Design Requirements	loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve. 302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.
Suggestions for ADA Compliance	Patch pothole to maintain a smooth, uninterrupted, solid surface.

Kanawha Charleston Health Department	
Issue(s)	Accessible parking signage is not properly displayed.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Kenna Homes Community Center	
Issue(s)	Handrail extensions are not installed. Door hardware is not accessible. Long walk to voting area.
2010 ADA Standards for Accessible Design Requirements	405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505. 404.2.7 Door hardware is operable with one hand and does not require tight grasping, pinching or twisting of the wrist. 206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site. 208.3.1 General. Parking spaces complying with 502 that serve a particular building or facility shall be located on the shortest accessible route from parking to an entrance complying with 206.4. Where parking serves more than one accessible entrance, parking spaces complying with 502 shall be dispersed and located on the shortest accessible route to the accessible entrances. In parking facilities that do not serve a particular building or facility, parking spaces complying with 502 shall be located on the shortest accessible route to an accessible pedestrian entrance of the parking facility.
Suggestions for ADA Compliance	Install handrail extensions as shown above to comply with the ADA standards. Change door hardware that complies with the ADA regulation. Move parking area closer to the door used during Election Day.

Lakewood Elementary

Issue(s)	Slope coming from main road to door used to access building is too steep. No signage for accessible parking. Accessible parking is located on the other side of the building.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site. 216.6 Signage at inaccessible entrances indicating the location of nearest accessible entrance. 405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12 (8.3%).
Suggestions for ADA Compliance	Add accessible parking signage that is compliant with the ADA guidelines as listed above. Regrade slope or add accessible ramp from road. Relocate or add temporary accessible parking to rear of the building where the polling is conducted on Election Day. Install a sign at the road entrance directing to the entrance for accessibility; or, purchase a mobile ramp for the road entrance.

Loudendale Community Center	
Issue(s)	No handrail extension installed.
2010 ADA Standards for Accessible Design Requirements	405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.
Suggestions for ADA Compliance	Install handrail extensions as depicted above to comply with the ADA guidelines.

Malden Elementary School	
Issue(s)	Accessible Parking signage not properly displayed.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

800 Indiana Avenue	
Issue(s)	No accessible parking spots marked, and no signage.
2010 ADA Standards for Accessible Design Requirements	<p>208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.</p> <p>208.2.4 Van Parking Spaces. For every six or fraction of six parking spaces required by 208.2 to comply with 502, at least one shall be a van parking space complying with 502.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	Re-stripe the parking lots, assuring that there are the minimum number of accessible, including van accessible, parking spaces. Install accessible parking signage at the required height that complies with the ADA regulation.

Mammoth Church	
Issue(s)	Ramp slope is too steep. Handrail extensions not installed.
2010 ADA Standards for Accessible Design Requirements	<p>405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.</p> <p>405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12 (8.3%).</p>
Suggestions for ADA Compliance	Regrade ramp to appropriate slope. Install proper handrail extensions.

Marmet Recreation Building	
Issue(s)	Uneven walkway to main entrance of the building. No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>206.2.1 Site Arrival Points. At least one accessible route shall be provided within the site from accessible parking spaces and accessible passenger loading zones; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve.</p>

	302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.
Suggestions for ADA Compliance	Repave area where there is the crack. Remount existing signage to the required height that complies with the ADA regulation.

Martin Luther King Jr. Community Center	
Issue(s)	Large crack on curb ramp. Curb ramp is too steep. No marked accessible parking.
2010 ADA Standards for Accessible Design Requirements	<p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.</p> <p>208.2.4 Van Parking Spaces. For every six or fraction of six parking spaces required by 208.2 to comply with 502, at least one shall be a van parking space complying with 502.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.</p> <p>405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12 (8.3%).</p>
Suggestions for ADA Compliance	Add accessible parking spots. Fix curb ramp surface cracks and regrade ramp. Install accessible parking signage to the required height that complies with the ADA regulation.

Mary Ingles Elementary School	
Issue(s)	Accessible parking signage not displayed properly.
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	Add accessible signage to the required height that complies with the ADA regulation.

McKinley Middle School	
Issue(s)	Accessible parking signage is not displayed properly.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the recommended height that complies with the ADA regulation.

Midland Trail Elementary	
Issue(s)	Accessible parking signage is not displayed properly.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the recommended height that complies with the ADA regulation.

Montrose Elementary School	
Issue(s)	No marked accessible parking.
2010 ADA Standards for Accessible Design Requirements	208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking <i>facility</i> is provided on a <i>site</i> , the number of <i>accessible spaces</i> provided on the <i>site</i> shall be calculated according to the number of <i>spaces</i> required for each parking <i>facility</i> . 208.2.4 Van Parking Spaces. For every six or fraction of six parking <i>spaces</i> required by 208.2 to comply with 502, at least one shall be a van parking <i>space</i> complying with 502. 502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Add appropriate number of accessible parking spots as recommended by the ADA. Add signage for accessible parking spots where needed. Install temporary accessible spots on Election Day.

Mount Calvary Baptist Church	
Issue(s)	Accessible parking spots do not have the proper signage. Handrails do not have the proper extensions on them.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.
Suggestions for ADA Compliance	Install proper signage to comply with the ADA standard listed above. Add handrail extensions where needed.

Mountain Heights Church	
Issue(s)	Accessible parking signage is not displayed properly. Doorknob into the building is not accessible. No handrail extensions.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505. 404.2.7 Door hardware is operable with one hand and does not require tight grasping, pinching or twisting of the wrist. Replace the inaccessible knob with level, loop or push hardware.
Suggestions for ADA Compliance	Install handrail extensions. Replace door hardware to accessible hardware. Remount existing signage to the recommended height that complies with the ADA regulation.

Nitro Elementary School	
Issue(s)	Rain grate is on the accessible entry way. Accessible parking sign is not properly displayed.
2010 ADA Standards for Accessible Design Requirements	302.3 Openings. Openings in floor or ground surfaces shall not allow passage of a sphere more than ½ inch (13 mm) diameter except as allowed in 407.4.3, 409.4.3, 410.4, 810.5.3 and 810.10. Elongated openings shall be placed so that the long dimension is perpendicular to the dominant direction of travel. 502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.

Suggestions for ADA Compliance	Remount accessible sign to ADA recommended height. On Election Day, cover grate with compliant mat or board.
---------------------------------------	--

Nitro High School	
Issue(s)	Accessible parking signage is not displayed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Nitro Women’s Club	
Issue(s)	Curb ramp is too steep. Curb ramp is cracked. Uneven surface to entrance. Doorknob is not compliant.
2010 ADA Standards for Accessible Design Requirements	404.2.7 Door hardware is operable with one hand and does not require tight grasping, pinching, or twisting of the wrist. 404.2.3 Door openings shall provide a clear width of 32 inches (815 mm) minimum. 405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12 (8.3%). 206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.
Suggestions for ADA Compliance	Replace door hardware. Fix crack and slop in curb ramp. Widen door opening.

Old Glory Freewill Baptist church	
Issue(s)	Parking lot is not paved, no solid surface. Door is not wide enough. Door hardware is not compliant. No handrail extensions.
2010 ADA Standards for Accessible Design Requirements	404.2.7 Door hardware is operable with one hand and does not require tight grasping, pinching or twisting of the wrist. 404.2.3 Door openings shall provide a clear width of 32 inches (815 mm) minimum. 206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.

	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.</p> <p>208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.</p> <p>208.2.4 Van Parking Spaces. For every six or fraction of six parking spaces required by 208.2 to comply with 502, at least one shall be a van parking space complying with 502.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.</p>
Suggestions for ADA Compliance	Change door hardware to one that is suggested by the ADA. Widen the door opening to comply with ADA standards. Pave the parking lot and provide one accessible route to the main entrance. Once parking lot is paved ensure that there is adequate amount of parking spots as suggested by the ADA. Add handrail extensions.

Overbrook Elementary School	
Issue(s)	Accessible parking signs are not properly displayed.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.

Parkland Terrace	
Issue(s)	Accessible parking signage is not properly displayed. Drain grate in the accessible parking spot. No curb cut out which causes a large lip off sidewalk.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.

	<p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>302.3 Openings. Openings in floor or ground surfaces shall not allow passage of a sphere more than ½ inch (13 mm) diameter except as allowed in 407.4.3, 409.4.3, 410.4, 810.5.3 and 810.10. Elongated openings shall be placed so that the long dimension is perpendicular to the dominant direction of travel.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.</p>
Suggestions for ADA Compliance	Add accessible parking signage as recommended by the ADA. Add a curb ramp to allow for a smooth surface. Relocate accessible spot away from the grate or use a ADA accessible mat.

Piedmont Elementary	
Issue(s)	No marked accessible parking spots. No accessible route. Individual has to use road as path of travel to curb cutout.
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.</p> <p>208.2.4 Van Parking Spaces. For every six or fraction of six parking spaces required by 208.2 to comply with 502, at least one shall be a van parking space complying with 502.</p> <p>216.6 Signage at inaccessible entrances indicating the location of nearest accessible entrance.</p>
Suggestions for ADA Compliance	Add appropriate number accessible parking spots. Place accessible parking signage. Have one accessible route to main entrance. Place signage showing where accessible entrance is and accessible path.

Pinch Elementary School	
Issue(s)	Accessible parking signage is not properly displayed.
2010 ADA Standards for	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs

Accessible Design Requirements	identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Point Harmony Elementary School	
Issue(s)	Ineffective curb ramp
2010 ADA Standards for Accessible Design Requirements	206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site. 302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. 303.4 Changes in level greater than ½ inch (13 mm) high shall be ramped and shall comply with 405 or 406.
Suggestions for ADA Compliance	Regrade ramp to meet evenly with the road.

Pratt Town Hall	
Issue(s)	Door handle has the wrong hardware. Accessible parking signage is not displayed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 404.2.7 Door hardware is operable with one hand and does not require tight grasping, pinching or twisting of the wrist.
Suggestions for ADA Compliance	Remount existing accessible parking signage to the recommended height. Change door hardware to ADA acceptable hardware.

Pratt Elementary School	
Issue(s)	Broken concrete along walkway to building. Accessible Parking signage is not properly displayed.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.

	<p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302.</p>
Suggestions for ADA Compliance	Repave area that contains broken concrete. Remount existing accessible signage to the ADA recommended height.

Quick Community Center

Issue(s)	No paved parking lot. No marked accessible parking. Handrail does not start at the beginning of the ramp. No handrail extensions. Large surface cracks in ramp.
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p> <p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. Advisory 302.1 General. A stable surface is one that remains unchanged by contaminants or applied force, so that when the contaminant or force is removed, the surface returns to its original condition. A firm surface resists deformation by either indentations or particles moving.</p> <p>208.2 Minimum Number. Parking spaces complying with 502 shall be provided in accordance with Table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.</p> <p>208.2.4 Van Parking Spaces. For every six or fraction of six parking spaces required by 208.2 to comply with 502, at least one shall be a van parking space complying with 502.</p> <p>216.6 Signage at inaccessible entrances indicating the location of nearest accessible entrance.</p> <p>405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.</p>
Suggestions for ADA Compliance	Repave area that contains broken concrete. Mount accessible signage to the ADA recommended height. Create a paved parking area. Extend handrail to beginning of ramp. Add handrail extensions where necessary.

Rand Community Center

Issue(s)	No accessible parking signage. Ramp is too steep.
-----------------	---

2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 405.2 Slope. Ramp runs shall have a running slope not steeper than 1:12 (8.3%).
Suggestions for ADA Compliance	Place signage to the required height that complies with the ADA regulation. Regrade ramp slope.

Ruffner Elementary School	
Issue(s)	Large surface cracks. No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site. 302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. Advisory 302.1 General. A stable surface is one that remains unchanged by contaminants or applied force, so that when the contaminant or force is removed, the surface returns to its original condition. A firm surface resists deformation by either indentations or particles moving.
Suggestions for ADA Compliance	Repave area that is cracked and broken. Place signage to the required height that complies with the ADA regulation.

Ruthlawn Elementary	
Issue(s)	No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

Sharon Dawes Elementary School

Issue(s)	No accessible parking signage where needed. 6-inch lip to get into the door with no ramp.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign. 206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.
Suggestions for ADA Compliance	Add accessible parking signage where necessary and at the recommended height. Add a ramp. OR relocate the door used to the main entrance.

Shoals Elementary School	
Issue(s)	No accessible signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.

Sissonville Elementary School	
Issue(s)	No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.

Sissonville High School	
Issue(s)	No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.

Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.
---------------------------------------	--

South Charleston City Annex	
Issue(s)	The accessible parking signage is not placed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Remount existing signage to the required height that complies with the ADA regulation.

South Charleston Community Center	
Issue(s)	No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.

South Charleston Sanitary Board	
Issue(s)	No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.

St. Albans High School	
Issue(s)	No accessible parking signage.

2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation. Repaint parking lot striping.

St. Matthews Episcopal Church	
Issue(s)	The accessible parking signage is not placed at the proper height.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.

St. Paul A.M.E. Church	
Issue(s)	No handrail extensions. Off street parking with cracks filled with mud.
2010 ADA Standards for Accessible Design Requirements	206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site. 302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. Advisory 302.1 General. A stable surface is one that remains unchanged by contaminants or applied force, so that when the contaminant or force is removed, the surface returns to its original condition. A firm surface resists deformation by either indentations or particles moving. 405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.
Suggestions for ADA Compliance	Add handrail extensions. Repave entrance to provide a smooth surface.

Tiskewah Center	
Issue(s)	Accessible parking signage is not mounted at the proper height. Large pothole in parking lot. No handrail extensions.
2010 ADA Standards for Accessible	206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.

Design Requirements	<p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. Advisory 302.1 General. A stable surface is one that remains unchanged by contaminants or applied force, so that when the contaminant or force is removed, the surface returns to its original condition. A firm surface resists deformation by either indentations or particles moving.</p> <p>405.8 Handrails. Ramp runs with a rise greater than 6 inches (150 mm) shall have handrails complying with 505.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	Patch pothole. Add handrail extensions. Remount existing signage to the required height that complies with the ADA regulation.

Washington High Community Center	
Issue(s)	Large pothole that has been patched with gravel. Accessible parking signage is not placed properly.
2010 ADA Standards for Accessible Design Requirements	<p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. Advisory 302.1 General. A stable surface is one that remains unchanged by contaminants or applied force, so that when the contaminant or force is removed, the surface returns to its original condition. A firm surface resists deformation by either indentations or particles moving.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	Patch pothole with a solid, smooth surface. Accessible parking signage needs to be remounted at the appropriate height as recommended from the ADA.

Weberwood Elementary	
Issue(s)	Large surface crack in the walkway that is growing grass. There is a 5-inch lip to get into the door. Parallel parking spot is very steep. No accessible parking signage.
2010 ADA Standards for Accessible	<p>502.4 Floor or Ground Surfaces. Parking spaces and access aisles serving them shall comply with 302. Access aisles shall be at the same level as the parking spaces they serve. Changes in level are not permitted. EXCEPTION: Slopes not steeper than 1:48 shall be permitted.</p>

Design Requirements	<p>Advisory 502.4 Floor or Ground Surfaces. Access aisles are required to be nearly level in all directions to provide a surface for wheelchair transfer to and from vehicles. The exception allows sufficient slope for drainage. Built-up curb ramps are not permitted to project into access aisles and parking spaces because they would create slopes greater than 1:48.</p> <p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>302.1 Floor and ground surfaces shall be stable, firm, and slip resistant and shall comply with 302. Advisory 302.1 General. A stable surface is one that remains unchanged by contaminants or applied force, so that when the contaminant or force is removed, the surface returns to its original condition. A firm surface resists deformation by either indentations or particles moving.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	<p>Relocate accessible parking to a flat surface. Add accessible parking signage where necessary. Repave area leading to voting door entrance.</p> <p>Add a ramp to door with large lip.</p>

West Side Elementary School	
Issue(s)	Accessible parking signage is not placed at the proper height.
2010 ADA Standards for Accessible Design Requirements	<p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.</p>
Suggestions for ADA Compliance	Remount accessible parking signage at appropriate height as recommended by the ADA.

Belle Elementary School	
Issue	No accessible parking signage. Accessible parking is at the rear of the building by playground. Curb ramp is very steep.
2010 ADA Standards for Accessible Design Requirements	<p>206.2.2 Within a Site. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site.</p> <p>502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches minimum above the finish floor or ground surface measured to the bottom of the sign.</p>

	<p>216.6 Signage at inaccessible entrances indicating the location of nearest accessible entrance.</p> <p>403.3 An accessible route has running slope no greater than 1:20 (5%).</p>
Suggestions for ADA Compliance	Install a sign at the road entrance directing to the front entrance for accessibility; or, install a mobile ramp for the alley entrance. Regrade curb ramp. Install accessible parking signage that complies with ADA regulation.

The GRID in Montgomery	
Issue	No accessible parking signage.
2010 ADA Standards for Accessible Design Requirements	502.6 Identification. Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation “van accessible.” Signs shall be 60 inches minimum above the finish floor or ground surface measured to the bottom of the sign.
Suggestions for ADA Compliance	Install accessible parking signage to the required height that complies with the ADA regulation.

Several temporary solutions have been offered for making polling sites across Kanawha County accessible, and many of these solutions can easily be found online or at your local hardware store. An additional resource is West Virginia University’s Center for Excellence in Disabilities WVATS (West Virginia Assistive Technology System) program. This program has portable ramps to loan for free, although pick-up and drop-off of the ramps are required. Enclosed is a brochure with information for contacting WVATS.

The **2010 ADA Standards for Accessible Designs** referenced in this report can be found online at:

https://www.ada.gov/regs2010/2010ADAStandards/2010ADAStandards_prt.pdf

Four other valuable resources have been included for your reference:

- ADA Checklist for Polling Places <https://www.ada.gov/votingck.htm>
- The Americans with Disabilities Act and Other Federal Laws Protecting the Rights of Voters with Disabilities https://www.ada.gov/ada_voting/ada_voting_ta.htm
- Solutions for Five Common ADA Access Problems at Polling Places https://www.ada.gov/ada_voting/voting_solutions_ta/polling_place_solutions.htm
- ADA Quick Tips Tax Incentives <https://adata.org/factsheet/quicktips-tax>

The ADA requires that public entities ensure that people with disabilities can access and use all voting facilities. Because a mix of public and private facilities are used as polling places, public entities may ensure Election Day accessibility of a polling place by using low-cost, temporary measures, such as portable ramps or door stops, rather than making permanent modifications to a building. If temporary measures will not fix a barrier, and public entities are unable to make a permanent modification to fix the barrier, then the public entity must look for an alternative, accessible polling place.